

Product group: **661** Product number: **739474**

Spectrapak™ 310 Test kit - Low Pressure Boiler Water Test Kit.

Controlling key parameters is important to maintain control of boiler system water quality for protection against corrosion and scale formation.



## Product information

This product supersedes product no: **555474**

Compact test kit designs to encourage daily testing to maintain your boiler water within the desired level of quality.

Test Parameters: P Alkalinity, Chloride and pH

Recommended Limits: a. p-Alkalinity - 150-300 ppm as CaCO<sub>3</sub> b. Chlorides - 200 ppm maximum as Cl c. Condensate pH - 8.5-9.2 d. Hotwell temperature > 80°C

Supplied with Instruction sheet, 1 x Stirring Rod, 1 x 250ml glass bottle, 1 x pH Test Papers 7.5 to 14.0, 1 x pH Test Papers 6.5 to 10.0, 1 x pH Reagent 80g, 1 x Measuring Scoop, 3 x P Alkalinity Test Tablets btl. 250, 1 x Chloride Test Tablets btl.250.

## Features

- Sturdy plastic case
- Simple to use test kit
- Test methods included

## Benefits

- Helps you to protect valuable boiler system equipment from the damaging effects of corrosion and scale formation

## Specification

### General

Invent Hazard Material (IMO/IU) classification	C-55
--	------

## Documents

[Spectrapak-310-Test-Methods](#)

[SDoC and MD for IHM](#)

## Related products

### Accessories

**55557**  
SAMPLE BOTTLES 250ML (X2)

**555714**  
SHAKER TUBE 309 TEST KIT

**739458**  
CHLORIDE TEST TABLETS BOTTLES 2 X 250

**555664**  
P-ALKALINITY TABLETS (2 BOTTLES X 250)

**764418**  
pH POWDER SCOOP

**555706**  
PH PAPER + PH REAGENT

**778648**  
PLASTIC STIRRING RODS (10)

### Is accessory to

**698720**  
AUTOTREAT - 25 LTR

### Is frequently bought together with

**765018**  
ENVIROCLEAN 25 LTR

**571687**  
DISCLEAN 25 LTR

**739466**  
SPECTRAPAK 309

**571356**  
ROCOR NB LIQUID 25 LTR

**571364**  
VAPTREAT 25LTR

**This page is printed from:**

<https://www.wilhelmsen.com/product-catalogue/products/marine-chemicals/test-kits-and-reagents/water-test-kits/spectrapak-310/>