

Last updated: 30/04/2025 05:20:41

CONDENSATE CONTROL 25 LTR

Product group: 655 Product number: 774828

NALFLEET™ Condensate Control™ is blend of liquid neutralising amines boiler water treatment product designed for effective corrosion control and protection in steam and condensate systems.



Product information

This product supersedes product no: 571323

Features

- Easy to use liquid treatment
- Neutralises the acids occurring in the condensate system
- Volatilizes and carries over with the steam and so it is recycled
- Simple test to determine level of treatment
- Used for protection of condensate and feed water systems in boiler systems of all pressures

Benefits

- Dosage is economical and efficient
- Less maintenance required
- Lower operating costs and increased reliability

Specification

General

Invent Hazard Material (IMO/IU) classification	C-9
--	-----

Physical properties

Appearance	Colourless
Density [g/ml]	1.0
Form	Liquid
pH	12

Technical data

Not Compatible	Avoid copper, brass and aluminium
----------------	-----------------------------------

Documents

[SDoC and MD for IHM](#)

Directions for use

Dosage and Control

The condensate is tested for pH to determine the dosage level. The pH limits are 8.5-9.2. For an average system e.g. 10 m3, the dosage is approximately 0.65 ltr/day

Dosing Method

NALFLEET™ Condensate Control is best dosed continuously using an automatic dosing unit. The treatment can be dosed together with the oxygen scavenger.

Suitable dosage points are:

Boiler feed line after recirculation valve
Condensate pump discharge
NALFLEET™ Condensate Control can be fed using an automatic dosing system. Consult your WSS representative for specific dosing instructions.

Sampling and Testing

A representative sample of condensate should be drawn for analysis daily. The sample should always be taken from the same point, cooled and tested immediately. Follow the test kit instructions and log the results in Waterproof. The results should be sent to WSS as stated in the Waterproof instructions.

Condensate Control Dosing Parameters (all pressure groups)

Standard pH range is 8.5 to 9.2

Measured pH

If pH < 8.5: Increase Dosage by 25%. Retest after 24 hrs or shorter. **If pH within 8.5 to 9.2:** Within control. No adjustment needed, continue with routine monitoring. **If pH > 9.2:** Decrease dosage by 25%. Retest after 24 hrs or shorter.

These are recommended values based on experience and are in no way intended to replace the boiler manufacturer's specifications or company regulations.

It is important that regular testing is carried out to ensure levels of treatment are correct. Use dosage chart to maintain condensate pH between 8.5-9.2.

Related products

Is frequently bought together with

- 680843**
COOLTREAT AL 25 LTR
- 571364**
VAPTREAT 25LTR
- 571356**
ROCOR NB LIQUID 25 LTR
- 735977**
MAR-71 BIOCID 3X5L NOT IN USA&CAN
- 638676**
EVAPORATOR DEFOAMER 4X5 LTR
- 777701**
BWT LIQUID PLUS 25 LTR
- 777710**
NALFLEET 2000 25 LTR