

Product group: 657 Product number: 766402

Calcium Hypochlorite Granulate (4 x 5kg) is a potable grade chlorine release agent that can be used to chlorinate and control bacterial growth in Potable Water, Swimming Pools and Spas and for Grey Water Sterilisation.

Product information

This product supersedes product no: 741082

Features

- Contains a high level of available chlorine
- Convenient, fast dissolving granulate

Benefits

- Extended shelf life
- Easy to test (free chlorine)

Specification

General

CAS No.	7778-54-3
Invent Hazard Material (IMO/EU) classification	C-50

Physical properties

Performance data

Appearance	White solid granules		
Available Chlorine	min. 70%		
Density [g/ml]	1.0g/cm3		
Molecular Weight	143		
рН	11.6 (1% aqueous solution)		
Solubility	20g per 100g water at 20C		

Technical data

Water content	12.5%

Packaging, Handling, First Aid and Storage

Calcium Hypochlorite Granulate is highly corrosive and a strong oxidising agent. Avoid contact with eyes, skin and inhalation of vapours. Ensure ample ventilation at point of use. Wear impervious clothing, rubber gloves and goggles or face shield. Do not take internally. Wash contaminated skin with fresh water for at least 15 minutes and obtain medical aid. Flush eyes with clean water for at least 15 minutes and obtain medical aid. If swallowed do not induce vomiting, give plenty of water to drink and obtain medical aid immediately. If inhaled remove person to fresh air. Remove contaminated clothing and wash before re-use. Note: Do not give an unconscious person anything to drink.

Keep product dry in tightly closed containers when not in use. Store in a cool, dry, well ventilated area, away from heat or open flame.

Documents

SDoC and MD for IHM

Directions for use

Grams of Calcium Hypochlorite (70% available chlorine) required to achieve target free chlorine level.

System Volume m3	1m3	5m3	10m3	20m3
Free Chlorine mg/lit				
1mg/lit	1.4	7	14	28
5mg/lit	7	35	70	140
10mg/lit	14	70	140	280
50mg/lit	70	350	700	1400



Add proportionally as in the table, wait 20mins then test free chlorine level before next addition. Repeat until desired free chlorine level is achieved. Waters with a high chlorine demand, such as effluent and bilge water, may require substantially more product to achieve the required free chlorine level.

Related products

Is accessory to

656207 EVAPORATOR DOSING UNIT ON GRAVITY 777336 AQUAGUARD CW DOSING SYSTEM 777332 AQUAGUARD BW 2 PUMP DOSING SYSTEM

Consumables

768129 MD100 POOLCONTROL 6IN1 778419 POTABLE WATER TEST KIT 767020 POOLCHECK 6 IN 1 TEST KIT 6 PCS

Is frequently bought together with

 765018

 ENVIROCLEAN 25 LTR

 743146

 GAMAZYME TDS 5 KG BLUE SACH W/MINT

 589945

 GAMAZYME BTC 12 X1 LTR

 571356

 ROCOR NB LIQUID 25 LTR

 571752

 NATURAL HANDCLEANER 4X5 LTR

This page is printed from:

https://www.wilhelmsen.com/product-catalogue/products/marine-chemicals/water-treatment-chemicals/pool-chemicals/cal.-hypochlorite-granulate-4-x-5kg