

Last updated: 30/04/2025 05:19:25

RO MILD ACID CLEANER 25 LTR

Product group: 648 Product number: 777715

NALFLEET™ RO Mild Acid Cleaner is a membrane cleaner specifically designed to remove fouling by iron and light calcium carbonate scaling. The efficacy of RO Mild Acid Cleaner can be enhanced by the addition of RO Alkaline Cleaner to the cleaning solution although some minor pH correction may be necessary.



Product information

This product supersedes product no: **PC-77.11R, 777202**

The efficacy of RO Mild Acid Cleaner can be enhanced by the addition of RO Alkaline Cleaner™ to the cleaning solution although some minor pH correction may be necessary.

Storage Instructions: RO Mild Acid Cleaner should be stored at temperature above 15 °C. Below 15 °C the product can form precipitation.

Features

- Mild acid formulation
- Compatible with wide range of RO membranes
- Liquid formulation
- Certified by NSF in accordance with Standard 60

Benefits

- Helps to maintain RO performance
- Promotes the extension of membrane lifespan

Specification

General

Invent Hazard Material (IMO/EU) classification	C-49
--	------

Physical properties

Appearance	Clear light yellow
Density [g/ml]	1.14-1.22
Form	Liquid
pH	2.8 - 4.6

Technical data

Not Compatible	Mild steel, Brass, Viton O-rings, Polyurethane O-rings, Vinyl ester resin, Epoxy phenolic
----------------	---

Approvals

NSF International Certifies that this product conforms to the requirements of NSF/ANSI Standard 60 - Drinking Water Treatment Chemicals - Health Effects.
For off-line use only.

[NSF-Listing-23rd-Jan-2012](#)

Documents

[RO Product Flyer](#)

[SDoC and MD for IHM](#)

Directions for use

NALFLEET™ RO Mild Acid Cleaner is a membrane cleaner specifically designed to remove iron fouling. It also is effective against light calcium carbonate scaling. The efficacy of NALFLEET™ RO Mild Acid Cleaner can be enhanced by the addition of NALFLEET™ RO Alkaline Cleaner to the cleaning solution although some minor pH correction may be necessary.

NALFLEET™ RO Mild Acid Cleaner should always be used as recommended by the membrane manufacturer or equipment supplier, in respect to cleaning pH and temperature.

During normal operation, RO membranes can become fouled, which greatly reduces the efficiency of the system. Deposits build up on the membrane until they cause a reduction in permeate flow and loss in salt rejection. The effects of fouling can lead to poor water quality, loss in production, unscheduled downtime and membrane replacement. A regular maintenance and cleaning program can provide return on investment (ROI) results ranging from 100 to 250 % by maintaining low pump output pressures and extending the membrane's life. Elements should be cleaned whenever the normalized permeate flow rate or salt rejection decreases by 10-15 % or the differential pressure increases by 10-15 % from the original baseline data.

NALFLEET™ RO Mild Acid Cleaner conforms to the requirements of NSF/ANSI Standard 60 - Drinking Water Treatment Chemicals - Health Effects.

Sampling and Testing

There is no direct test for NALFLEET™ RO Mild Acid Cleaner concentration available.

Dosing and Control

NALFLEET™ RO Mild Acid Cleaner should be fed via a closed feed system. A closed feed system is defined as a system in which fluid is moved from a closed storage vessel into a treated media without exposure to the atmosphere except through normal venting or pressure relief devices.

Cleaning solutions should be prepared with chlorine-free product water to give a 4 % (by weight) solution, or 1 kg of NALFLEET™ RO Mild Acid Cleaner to every 25 kg of water. As NALFLEET™ RO MILD Acid Cleaner is buffered, the cleaning solution will stabilize at pH 3.6.

The cleaning time depends on the amount of fouling present but is usually completed within two to three hours. If the cleaning solution becomes red/brown in color, it must be changed as it has become exhausted. The NALFLEET™ RO Mild Acid Cleaner cleaning solution should always be neutralized with alkali and discarded after use.

Before returning the system to service, the operator must ensure that any residual cleaning product is removed from the membrane surfaces by thorough flushing. This may be done by monitoring the pH of the concentration until it returns to the same pH as the influent water.

Success Factors

Membrane fouling via deposit results in decreased production, unscheduled shutdowns, poor product water quality, and premature equipment failure. Cleaning an RO system when required by the membrane manufacturer's operating guidelines, will make it easier to restore membrane performance and maximize its life. Allowing a membrane system to excessively foul or scale often results in the premature replacement of the membrane elements. Heavy foulant layers or scale formations can block flow channels within the elements, making it nearly impossible to get a cleaning solution to penetrate the bulk of the foulant/scale. This can result in a dramatic increase in the amount of time required for a successful cleaning, assuming it is even possible

Related products

Consumables

- 768129
MD100 POOLCONTROL 6IN1
- 778419
POTABLE WATER TEST KIT

Is frequently bought together with

- 589945
GAMAZYME BTC 12 X 1 LTR
- 571356
ROCOR NB LIQUID 25 LTR
- 765018
ENVIROCLEAN 25 LTR
- 777852
RO.BISULPHITE 25 LTR LIQUID 38-40%
- 777718
RO ALKALINE CLEANER 25 LTR