

Last updated: 30/04/2025 05:22:26

RO.BISULPHITE 25 LTR LIQUID 38-40%

Product group: **648** Product number: **777852**

NALFLEET™ RO Bisulphite™ is a solution of sodium hydrogen sulphite (sodium bisulphite) used in the preservation of RO membranes and as a de-chlorinating agent.



Product information

This product supersedes product no: **L770007**

Features

- Liquid product
- Suitable for RO membrane preservation and dechlorination

Benefits

- Helps to maintain RO performance
- Concentrated product
- Easy to handle

Specification

General

Invent Hazard Material (IMO/IU) classification	C-9
--	-----

Physical properties

Density [g/ml]	1.30 to 1.34
Form	Light yellow liquid
Odour	Strong sulphur
pH	3.7-4.5

Approvals

Approved by The Norwegian Food Safety Authority

Documents

[RO Product Flyer](#)


[SDoC and MD for IHM](#)

Directions for use

Procedures

A. De-Chlorination

If the feed water to the RO system contains free chlorine it must be removed otherwise it can breakdown the RO membrane. NALFLEET™ RO Bisulphite is a 40% solution of Sodium Bisulphite (NaHSO3) It undergoes the reaction below with free chlorine:



A dose rate of 3.66ml/m3 of NALFLEET™ RO Bisulphite should be applied for each 1ppm of free chlorine in the feed water. Use a suitable free chlorine test kit to monitor reduction in free chlorine levels. For continuous applications a suitable storage tank and chemical dosing pump should be used.

The solution should be dosed as close to the RO system as possible (to keep as much of the pre-treatment as possible in contact with chlorine e.g. after the cartridge filters). However, if the free chlorine level is high, the solution should be dosed prior to the antiscalant injection point (or antiscalant dosage adjusted to compensate for chlorine attack, as some antiscalants are attacked by free chlorine). The antiscalant and NALFLEET™ RO Bisulphite dosing point should be far enough apart to prevent neat product mixing.

B. Lay up and preservation of Reverse Osmosis and Nano-Filtration membranes and systems. (Polyamide, TFC, CPA membranes)

It is necessary to preserve membranes when the RO or NF system is taken out of production for more than 24 hours. Failure to do so may allow biofilms to form on the surface of the membranes which will cause operational problems upon restarting the system. Prior to shutdown, the RO needs to be cleaned in-line with operational guidelines and MUST be flushed with RO permeate. After flushing with permeate, the preservation solution can be pumped into the RO system. Note: It has to be verified that the plastic materials (including pressure vessels) used in the membrane plant are resistant to sodium bisulphite. Otherwise cracks might occur in the plastic materials.

Prepare a solution of 2.5 % NALFLEET™ RO Bisulphite
Fill the entire system to be preserved with the solution
It is recommended to measure the pH regularly. A fresh solution is needed when the pH < 3 A fresh solution is also needed when the liquid becomes turbid or changes colour. Regular inspections (weekly) are recommended.
NALFLEET™ RO Bisulphite conforms to the requirements of NSF/ANSI Standard 60 - Drinking Water Treatment Chemicals - Health Effects.

Related products

Consumables

768129
MD100 POOLCONTROL 6IN1
778419
POTABLE WATER TEST KIT

Is frequently bought together with

607826
AQUATUFF 25 LTR
698720
AUTOTREAT - 25 LTR
589945
GAMAZYME BTC 12 X 1 LTR
909001
SODIUM HYPOCHLORITE POTABLE GRADE
571356
ROCOR NB LIQUID 25 LTR